



APPROVALS®

Certificate of Approval

Certificate No.: SAA-152275-EA

Certificate Holder: Yueqing Langir Electric Co., Ltd.
4F, No.188 Liuqing North Road, Liushi,
Wenzhou,
P.R. China

Class Description: Miniature Overcurrent Circuit-Breaker
Product Description: DC Circuit Breaker 1P, 2P, 3P, 4P
Utilisation Category A

Brand Name: langir

Model No.: JB

Markings:

250Vdc (1P)

500Vdc (2P)

750Vdc (3P)

1000Vdc (4P)

In= 1A, 2A, 3A, 4A, 6A, 10A, 16A, 20A, 25A,
32A, 40A, 50A, 63A

$I_{cu}=I_{cs}= 10kA$

Instantaneous tripping curve C-type, D-type, K-type

Standard: AS 60947.2:2005

AS 60947.1:2004

Conditions: Nil

Approval Mark: SAA-152275-EA or RCM

Date First Registered: 14 December 2015

Date of Expiry: 14 December 2020


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 14-12-15 152275/1